

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>001128</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>02</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>08/12/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>FRIENDS FELLOWSHIP COMMUNITY</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>2030 CHESTER BLVD RICHMOND, IN 47374</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p><b>INITIAL COMMENTS</b></p> <p>A Life Safety Code State Licensure Survey was conducted by the Indiana State Department of Health.</p> <p>Survey Date: 08/12/16</p> <p>Facility Number: 001128 Provider Number: 001128 AIM Number: None</p> <p>At this Life Safety Code survey, Friends Fellowship Community was found in compliance with Requirements of the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility with a basement was determined to be of Type V (111) construction and fully sprinkled. The facility has a fire alarm system with smoke detection on all levels including the basement, the corridors, spaces open to the corridors and hard wired smoke detectors in the 24 Courtyard Hall resident room and battery operated smoke detectors in the 35 Health Center Hall resident rooms . The facility has a capacity of 92 and had a census of 72 at the time of this visit.</p> <p>All areas where residents have customary access were sprinkled and all areas providing facility services were sprinkled.</p> <p>Quality Review completed on 08/17/16 - DA</p>	S 000		

Indiana State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE